

पत्र संख्या/No. A-6/3/2025-kol./42

भारत सरकार/Government of India
सूचना और प्रसारण मंत्रालय/Ministry of Information and Broadcasting
पत्र सूचना कार्यालय/ Press Information Bureau
कोलकाता/Kolkata

18/3, Uday Shankar Sarani, Kolkata 700095.

Dated

13/2/26

TENDER NOTICE

This office intends to uninstall of 18nos. of Office air conditions from 8, Esplanade East Kolkata 700069 and installation of same to 18/3, Uday Shankar Sarani, 03rd Floor, Kolkata 700095. An AC shifting quotation should clearly itemize dismantling, transport, and installation costs, including labor, materials (copper pipe, insulation, cabling), and taxes. Interested parties may submit their rate separately mentioning Unit Price and TAX/GST/in the Quotation. Quotation to be submitted on or before 20.02.2026 up to 02.00pm to the office Tender Box. No Quotation will be entered after the schedule date & time. The undersigned also reserves the right to accept or reject any quotation without showing any reason.

The details of AC machines of PIB Kolkata is attached with the Tender.

Criteria:-

1. Office must be situated at West Bengal
2. GST Registration
3. PAN Number

Any damage occurred during shifting of ACs, this will be borne by the party.
Enclos:- Details of AC Machine of PIB Kolkata

1. Notice Board
2. Respective File

(Santanu Sinha)/ (शांतनु सिन्हा)

Administrative Officer/ प्रशासनिक अधिकारी

शांतनु सिन्हा / Santanu Sinha
प्रशासनिक अधिकारी / Administrative Officer
पत्र सूचना कार्यालय / Press Information Bureau
भारत सरकार / Govt. of India
कोलकाता / Kolkata

(Santanu Sinha)/ (शांतनु सिन्हा)
Administrative Officer/ प्रशासनिक अधिकारी

शांतनु सिन्हा / Santanu Sinha
प्रशासनिक अधिकारी / Administrative Officer
पत्र सूचना कार्यालय / Press Information Bureau
भारत सरकार / Govt. of India
कोलकाता / Kolkata



DETAILS OF AC MACHINE OF PIB KOLKATA

<u>SL NO</u>	<u>CAPACITY (TON)</u>	<u>COMPANY</u>	<u>LOCATION</u>
1	1.5	SAMSUNG	DG
2	1.5	SAMSUNG	Director
3	1.5	SAMSUNG	RNI
4	1	voltas	JD
5	1.5	voltas	DD
6	2	voltas	ADM. SEC
7	2	voltas	NEWS ROOM
8	2	voltas	COMPUTER ROOM
9	2	voltas	DG
10	1	voltas	ADM. SEC <u>(inactive)</u>
11	1.5	voltas	NEWS ROOM
12	1.5	voltas	PA OF DG
13	2	voltas	MEDIA SC.
14	2	voltas	MEDIA SC.
15	2	voltas	LIBRARY
16	2	voltas	ADM. SEC
17	2	voltas	ADM. SEC
18	2	voltas	ADM. SEC